



PSD15/3/FP/7/1271

Protection and Safety Directorate  
Dated: 23<sup>rd</sup> October 2017

**M/S. AL Mezal General Trading B.S.C**  
**P.O.Box No. 70303,**  
**SITRA**  
**Kingdom of Bahrain**

Dear Sir,

**“MARMOX” MULTI BOARDS**  
**(THERMAL INSULATION PRODUCT)**

Thank you for your submittal dated 14<sup>th</sup> September, 2017, regarding the above subject.

This is to confirm you that the General Directorate of Civil Defence have no objections to use the “Marmox” Multi Board (Thermal Insulation) for the car park ceiling protection without covering plaster board as the material is already fire rated subject to the approval of other concerned authorities.

*Yours faithfully,*

*For Colonel*  
*Director Protection & Safety Directorate*  
*General Directorate of Civil Defence*  
*Colonel Sa'ad Hassan Al-Naimi*



/sna.