



شهادة تسجيل نظام عزل حراري
Registration Certificate of Thermal Insulation System
(Ministerial Order No. 8/1999)

Certificate No: TIS16008 **رقم الشهادة:**
Registration Date: 20/07/2016 **تاريخ الإصدار:**
Issued to: Al-Mezal General Trading **أصدرت إلى:**
Kingdom of Bahrain
System Name: Pleko Exterior Insulation & Finish System **اسم النظام:**
EIFS
Manufacturer Name: Pleko Systems, KSA **اسم المصنع:**
Valid Until: 01/07/2018 **تاريخ الصلاحية:**

مكونات نظام العزل الحراري Thermal Insulation System Components	
الرقم Sr. No.	تفاصيل المنتج Product Details
1	Expanded Polystyrene Sheet (Plastbau Arabia Co. - KSA), density 20kg/m ³ & thermal conductivity 0.041W/mK.
2	Pleko adhesive.
3	Pleko reinforced fiberglass mesh.
4	Pleko Mechanical Fastener.
5	Pleko base/finish coat.

Conditions:

- The above thermal insulation system is to be used as described above for external walls, provided the overall U-value for the wall does not exceed 0.75 W/m² °C.
- The owner of this system is responsible; to ensure that the system is carried out by an approved applicator, for supplying all the accessories associated with it, and for any consequences that may result from the use of this system.
- This approval is granted for thermal insulation only. Any additional approvals / permissions required should be sought from the concerned authorities.
- The TIU should not be held responsible for any consequences that may result from the use of this system.

(Handwritten signature)



Electricity Conservation Section